Strojírenský zkušební ústav, s.p. (Engineering Test Institute, Public Enterprise) Hudcova 424/56b, 621 00 Brno, Czech Republic



Page 1 of 24



TEST REPORT 31-9690/T

Product:

Hot-water boiler for solid fuel (wood pellets - C1) with

automatic fuel supply

Type designation:

ECO TOP 33

Versions:

Customer:

Topling d.o.o.

Vojvode Stepe br. 6 78340 Prnjavor

Bosnia and Herzegovina

Manufacturer:

Topling d.o.o. Vojvode Stepe br. 6

78340 Prnjavor

Bosnia and Herzegovina

Person responsible for re-

view and evaluation:

Ing. Stanislav Buchta

Report issue date:

2016-06-20

Distribution list:

1 copy to the Engineering Test Institute

1 copy to the Customer

Strojírenský zkušební ústav, s.p.



The tests were conducted on the basis of Order B-53642 dated 2015-08-10 (received on 2015-08-11), Contract B-53642/31 and amendment D1, D2 and D3 of Contract B-53642/31.

I. Product description, intended use and mode of application

The Hot-water boilers for solid fuel (wood pellets – C1) with automatic fuel supply, ECO TOP 33 is intended for heating of large residential buildings and similar buildings. The boiler is designed for burning of wood pellets – C1. The boiler assembly comprises the boiler body, boiler burner, feed screw and the fuel chamber (storage of fuel). The boiler body is made of welded steel components. The boiler body is thermally insulated with mineral felt.

Further detailed descriptions of individual assembly groups are provided in the enclosed technical documentation to Task 31-9690.

II. Sample tested

Boiler output versions that are the subject of the proceedings:

(table 1)

Boiler output version	Heat output	Place of testing
ECO TOP 33	33 kW	SZU

Visual inspection, testing and evaluation were carried out by lng. Pavel Fojtů, Test Engineer, at the test station of SZU in Brno, in 05/2016.

The tests were performed with the measurement and test equipment with valid calibration.

III. Measuring and test equipment

No.	Description	Inventory number	Calibration valid until	Accuracy
1.	Combustion product analyser, Horiba, type 680 P	92-0004	calibration prior to each measurement	see CRM 103000237769 see CRM 103000237770
2.	Weighing machine	02-2290	10/2017	see CS 6051-CS-H- 0651-10
3.	Water meter, NW 20	02-1575	03/2017	see CS ACS-P/006/2009
4.	Data collection system	02-2241	12/2017	see CS 110002
5.	Moisture meter, ther- mometer	11-6258	11/2017	see CS 7630F/09
6.	Barometer	11-2541	11/2017	see CS 613-CS-K011-08
7.	Draught gauge	11-7275	01/2018	see CS 0144F/11
8.	Stop watch	99-0760	10/2017	see CS 2850E-07
9.	Calorimeter, IKA, type C 5000	02-2236	03/2017	± 0,12 MJ/kg
10.	Elemental analyser, Perkin Elmer, type 2400 CHNS	02-2107	03/2017	± 0,2 % rel.
11.	Gravimat, SHC 501	02-2328	12/2017	see CS 090177 (8,9), 090180
12.	Laboratory weighing machine	02-1458	06/2017	see CS 6051-CS-H376- 09
13.	Weighing machine, Ohaus MB 45	02-2274	06/2017	see CS 6051-CS-H374- 09
14.	Manometer	18-3336	06/2017	see CS 130052
15.	Prandtl tube, 0.3 m	ME 484	11/2017	see CS 5012-CS-RS090- 09
16.	Psychrometer H 4220	92-0005	12/2017	see CS 090176
17.	Electrometer	03524781	03/2022	see CS 002/12/E

IV. Results of tests and evaluation

			_	Evaluation	
No. Requirement	Technical standard, regulation applied	Source materi- als	Test	Evalua tion	
1.	Pressurized component tightness and strength test (1001.1*)	ČSN EN 303-5:2013 Art. 5.4, 5.4.1, 5.4.2	Page 5	+	
2.	Surface temperature test (1003*)	ČSN EN 303-5:2013 Art. 5.12, 5.16.4, 4.3.6	Pages 6 - 7	+	
3.	Test of heat output, input and efficiency(1004.1*) Test of combustion prod- uct temperature (1004.2*)	ČSN EN 303-5:2013 Art. 4.4.2, 4.4.3, 5.7, 5.8, 5.10 ČSN EN 303-5:2013 Art. 4.4.3	Pages 8 - 10	+	
4.	Combustion efficiency test – emissions (1005.1*)	ČSN EN 303-5:2013 Art. 4.4.7, 5.7.3, 5.7.4, 5.9, 5.10.4	Pages 11 - 12	+	
		ČSN EN 303-5:2013 Annex C, Deviation from Austria, C.2.2, C.2.3	Pages 13 - 14	+	
		ČSN EN 303-5:2013 Annex C, C.3 Deviation from Croatia	-	0	
		ČSN EN 303-5:2013 Annex C, Deviation from Denmark , C.4.1, C.4.2	Pages 15 - 26	+	
	Test of heat output, input and efficiency	ČSN EN 303-5:2013 Annex C, Deviation from Germany, C.5.1, C.5.2	Pages 17 - 18	-	
5.	(1004.1*) Combustion efficiency test – emissions (1005.1*)	ČSN EN 303-5:2013 Annex C C.6 Deviation from Switzerland	Pages 19 - 20	+	
		ČSN EN 303-5:2013 Annex C C.8 Deviation from Italy	-	o	
6.	Test of control, regulation and safety elements (1006.1*) Combustion efficiency test – emissions (1005.1*)	ČSN EN 303-5:2013 Art. 5.13, 5.14, 5.16.2, 5.16.3 ČSN EN 303-5:2013 Art. 5.9, 5.10.4	Pages 21 - 23	+	

Note:

No.: 1 - 6

(**) Not a test

Evaluation:

- Requirement fulfilled
- Requirement not fulfilled
- х 0 Not assessed
- Not applicable



Accredited test

number:

1001.1* Test title: Pressurized component tightness and strength test

Test method:

ČSN EN 303-5:2013

Art. 5.4, 5.4.1, 5.4.2

Sample tested:

ECO TOP 33

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement	Requirement specification	Test evaluation	Note
Pressure test for boilers of sheet or sheet metal of	CONTENTOO		
non-ferrous metal	5:2013 Art. 5.4		1
Tests to be carried out before production The type test pressure is 2 × PS using hydraulic pressure where PS is the maximum permissible operating pressure. The test period shall be at least 10 min and if it is to apply to a range of boilers, the test shall be carried out on at least 3 boiler sizes (smallest, medium, and largest size). No leakage or noticeable permanent deformation shall occur during the test.	ČSN EN 303-	+	Enclosed technical documenta- tion.
A record shall be made of the test, including the following details: - exact description of the boiler tested by stating the draw-	5:2013 Art. 5.4.1	+	
ing number;	1	T	
- test pressure in bar and duration of the test;		+	
- test result;		+	
- place and date of the test, including the names of persons carrying out the test.	0	+	
The test report shall be signed by, as a minimum, the works tester responsible and one witness.		+	
Test during production Each boiler shall be tested during the production and the test pressure shall be at least 1.43 × <i>PS</i> .	ČSN EN 303- 5:2013 Art. 5.4.2	+	

Test evaluation:

No leakages or visible permanent deformations appeared during the test.



Accredited test

number:

1003* Test title: Surface temperature test

Test method:

ČSN EN 303-5:2013 Art. 5.12, 5.16.4, 4.3.6

Sample tested:

ECO TOP 33.

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement	Requirement specification	Test evalua- tion	Note
Surface temperature The mean surface temperature shall be measured at nominal heat output. In order to do this, a minimum of 5 points on each boiler surface shall be measured. Under the same conditions, the critical temperatures (e.g. boiler doors, operating levers) shall be measured.	ČSN EN 303- 5:2013 Art. 5.12	+	
The surface temperature on the outside of the boiler (including the bottom and doors but not including the flue gas outlet and maintenance openings of natural draft boilers) shall not exceed the room temperature by more than 60 K when tested in accordance with 5.12. The requirement for the bottom is not applicable for instances when the manufacturer declares that the boiler is to be installed on a non-combustible base. When tested in accordance with 5.12, the surface temperature of operating levers and all parts which shall be touched by hand during operation of the boiler shall not exceed the room temperature by more than the following values: - 35 K for metals and similar materials; - 45 K for porcelain and similar materials.	ČSN EN 303- 5:2013 Art. 4.3.6	+	
Resistance to thermal conductance Temperature measurement shall be performed on the surface of the stoking device at the place next to the fuel line but within a maximum distance which shall be less than 1 m against the feeding direction from the inner wall of the combustion chamber. For boilers with integrated hopper, the temperature measurement shall be performed on the surface of the stoking device at the place next to the integrated hopper but within a maximum distance which shall be less than 1 m against the feeding direction from the inner wall of the combustion chamber. In addition, the highest surface temperature of the hopper shall be measured.	ČSN EN 303- 5:2013 Art. 5.16.4	+	



Measurement results: ECO TOP 33

	f boiler walls, doors and cov		
Boiler type	ECO T	OP 33	
Fuel type	Wood Pe	ellets - C1	
Heat output	Nominal	Minimal	
ambient temperature (°C) humidity (%) air pressure (kPa)	22.9 48.8 98.19	23.5 50.1 98.25	
Front wall	34.8	32.3	
Rear wall	40.1	36.1	
Right wall	34.0	33.6	
Left wall	32.0	30.8	
Upper wall	36.4	35.4	
Lower wall	52.6	51.5	
Temperature	s of control elements (°C):		
Boiler cover (metal)	33	3.8	
Handle of lower door (metal)	34	1.9	
Handle of hopper (metal)	27.5		
ower side of fuel hopper (metal)	27.1		
nterior side of fuel hopper (metal)	50.6		
Fuel feeder	54.8		

<u>Measurement uncertainty:</u> $2 \, ^{\circ}\text{C}$ for temperatures within the range of $(0 \div 250) \, ^{\circ}\text{C}$

"The above-specified extended measurement uncertainties are calculated as a factor of the measurement uncertainty and the extension coefficient, k=2, corresponding to the coverage certainty of 95% as regards standard classification. The uncertainties do not reflect the impact of sample taking and lack of homogeneity. The standard uncertainty was determined in accordance with Document EA 4-02."

<u>Test evaluation:</u> The specified temperature rise values have not been exceeded.

Report 31-9690/T Page 8 of 24



Accredited test

1004.1* Test title: Test of heat output, input and efficiency

number: 1004.2*

Test of combustion product temperature

Test method:

ČSN EN 303-5:2013 Art. 4.4.2, 4.4.3, 5.7 to 5.10

Sample tested:

ECO TOP 33

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Average measured and calculated values (solid fuels):

Test:		I,	II.	
Boiler type:		ECO 1	ECO TOP 33	
Output tested:		Nominal	Minimum	
Fuel type:		Wood pe	ellets - C1	
Combustion period, (automatic) stoking		Minimal	ly 6 hours	
Nominal heat output (specified by manufacturer)	[kW]	33	33	
Flue gas temperature	[°C]	82.3	65.9	
Fuel mass added	[kg/h]	6.879	2.090	
Inlet water temperature	[°C]	56.3	71.9	
Outlet water temperature	[°C]	75.3	85.0	
Temperature of the entering cold water	[°C]	12.3	13.6	
Cooling water flow rate	[m3/h]	1.4339	0.6140	
Draught	[Pa]	10.3	10.2	
Ambient temperature	[°C]	22.5	22.1	
Relative air humidity	[%]	32.3	42.8	
Barometric pressure	[kPa]	98.38	98.69	

Analysis of combustion products:

Test (period of burning):		1.	II.
Oxygen O ₂	[%]	8.85	12.70
Carbon dioxide CO ₂	[%]	12.42	8.44
Carbon monoxide CO	[ppm]	238	184
Higher hydrocarbons THC/OGC	[ppm]	6	4
Nitrogen oxides NOx	[ppm]	72	51
Sulfur oxides SO ₂	[ppm]	0	0

Report 31-9690/T Page 9 of 24



Auxiliary combustion values (solid fuels):

Test (period of burning):		I.	H.
Stoichiometric oxygen volume	[m ³ /kg]	0.896	0.895
Stoichiometric air volume	[m³/kg]	4.266	4.261
Stoichiometric volume of dry combustion products	[m ³ /kg]	4.247	4.242
Maximum content of CO ₂	[%]	20.63	20.63
Stoichiometric air multiple	[-]	1.72	2.52
Volume of dry combustion products. actual	[m ³ /kg]	7.040	10.343
Content of H ₂ O in combustion air	[m ³ /kg]	0.067	0.126
Content of H ₂ O in combustion products	[m ³ /kg]	0.738	0.797

Calculated values - thermal overview

Test (period of burning):		1.	II.
Loss of sensible heat of combustion products	[%]	3.6	3.8
Loss of gas underburning	[%]	0.1	0.1
Loss of mechanical underburning	[%]	0.1	0.2
Loss of heat transfer into environment	[%]	1.9	5.5
Total loss	[%]	5.8	9.6
Efficiency indirect method	[%]	94.2	90.4
Fuel mass added - actual	[kg/h]	6.899	2.097
Heat input	[kW]	33.3	10.1
Heat output	[kW]	31.3	9.1
Uncertainty of determining heat output	[kW]	1.3	0.4
Efficiency – direct method	[%]	93.7	90.0
Output / nominal output	[%]	94.7	27.6

At nominal output, when burning **Wood pellets – C1**, the boiler efficiency meets the requirements applicable to **Class 5** as per ČSN EN 303-5:2013, Fig. 1.

The measured heat output is within the \pm 8% tolerance;

Boiler Class 5;

At nominal output, combustion product temperature is less than 160 K above the ambient temperature;

When burning Wood pellets – C1, the period of burning is more than 6

The minimum heat output is less than 30% of nominal heat output.

Test evaluation:

Test results:

ECO TOP 33

Electricity consumption

During the tests, the electrical consumption shall be determined according to EN 15456.

The values for maximum consumption, for stand-by, nominal heat output and minimum heat output shall be stated in the test report. For boilers with automatic feeding systems (fuel line), the electrical consumption of the boiler and the fuel line shall be determined and stated separately.

The average electrical power consumption during stand by shall be measured for a minimum duration of 10 min and shall be stated in watts. In cases where control operations influence the intrinsic energy consump-

tion, a longer duration might be necessary.

Maximum electrical input	507 W
Electrical input at nominal heat output	45 W
Electrical input at minimum heat output	21 W
Electrical input for STAND BY mode	3 W
Maximum electrical input for ignition system	400 W
Maximum electrical input for fuel supply (fuel line)	40 W

Fuel analysis

Fuel type	Wood pellets – C1			
Analytical indicator	Symbol	Unit	Value	Uncertainty
Higher heating value	Q _s	[MJ/kg]	18.72	0.22
Lower heating value	Q _j	[MJ/kg]	17.40	0.22
All water in original condition	W ^r _t	[% by weight]	6.00	0.05
Ash	Α	[% by weight]	0.25	0.03
Carbon	С	[% by weight]	47.39	0.24
Hydrogen	Н	[% by weight]	5.38	0.20
Nitrogen	N	[% by weight]	0.09	0.14
Sulphur	S	[% by weight]	0.000	0.000
Chlorine	Cl	[% by weight]	0.007	0.001
Oxygen – calculation for 100%	0	[% by weight]	40.88	
Conversion factor f _{emis} for emissions in [mg/m3] to [mg/MJ]	f _{emis}	[-]	0.24462	

Note: Sample in original condition

Measurement uncertainty: Specified in Measurement results

"The above-specified extended measurement uncertainties are calculated as a factor of the measurement uncertainty and the extension coefficient, k=2, corresponding to the coverage certainty of 95% for standard classification. The uncertainties do not reflect the impact of sample taking and lack of homogeneity. The standard uncertainty was determined in accordance with Document EA 4/02".



Accredited test

number:

1005.1* Test title: Combustion efficiency test - emissions

Test method:

ČSN EN 303-5:2013

Art. 4.4.7, 5.7.3, 5.7.4, 5.9, 5.10.4

Sample tested:

ECO TOP 33

Measuring equipment used:

Chapter III - Measuring and test equipment

Requirement	Requirement specification	Test evaluation	Note
Emission limits Combustion shall be of low-emission. This requirement shall be satisfied if the emission values shown in Table 6 are not exceeded when operating at nominal heat output or, in the case of boilers with heat output range, when operating at nominal heat output and minimum heat output, in accordance with 5.7, 5.9 and 5.10.	ČSN EN 303- 5:2013 Art. 4.4.7	÷	

Table 6

	II.	Nominal heat					Emission lim	its						
		output	CO			ļ .	OGC/THC			Dust				
Stoking	Fuel			mg/m³ at 10% O ₂										
		kW	Class	Class	Class	Class	Class	Class	Class	Class	Class			
	()		3	4	5	3	4	5	3	4	5			
Manual Biogenic	≤ 50	5000			150	[
	1	> 50 ≤ 150	2500	7		10C	50	1	150	75	60			
		> 150 ≤ 500	1200	4200	700	100		30						
Fossil	≤ 50	5000	1200	700	150	50	30] /3	.60				
	3	> 50 ≤ 150	2500			100			125					
		> 150 ≤ 500	1200			100								
Automatic	Biogenic	≤ 50	3000	ĺ		100			II II					
		> 50 ≤ 150	2500			80	1		150	60				
		> 150 ≤ 500	1200	1000	500	80	30		1		40			
	Fossil	≤ 50	3000	1000	500	100		20 125						
		> 50 ≤ 150	2500	9		80			125					
		> 150 ≤ 500	1200			80								

NOTE 1: The dust values in this Table are based on the experience of the gravimetric filter method. The method used needs to be referred to in the test report. The particulate matter emission measured according to this European Standard does not include condensable organic compounds which may form additional particulate matter when the flue gas is mixed with ambient air. The values are therefore not directly comparable with values measured by dilution tunnel methods. Neither can they be directly translated into ambient air particulate concentrations.

NOTE 2: Additional test methods and emission limits which apply in some countries are given in the A-Deviations in Annex C.

^{*} Referred to dry exit flue gas, 0 °C, 1013 mbar.

^b Boilers of class 3 for type E-fuels according to 1.2.1 or e-fuels according to 1.2.3 in this Table and marked with the classification E-fuels and e-fuels do not need to fulfil the requirements for the dust emissions. The actual value shall be stated in the technical documentation and shall not exceed 200 mg/m3 at 10 % O2.



Measurement results: ECO TOP 33 - Wood pellets - C1

		Average values										
Boiler			Meas	ured values	Converted values O ₂ =10%							
output	O ₂ [%]	CO ₂ [%]	CO [ppm]	OGC/THC [ppm]	NO _x [ppm]	Dust [mg/m³]		OGC/THC [mg/m ³]		Dust [mg/m³]		
Nominal	8.85	12.42	238	6	72	32	270	8	134	29		
Minimum	12.70	8.44	184	4	51	26	304	8	140	34		

Test evaluation:

ECO TOP 33 - Wood pellets - C1 meets at nominal and minimum output the emission requirements for Class 5, as per ČSN EN 303-5:2013 Table 6.



Accredited test number:

1004.1* Test title:

1005.1*

Test of heat output input and efficiency Combustion efficiency test - emissions

ČSN EN 303-5:2013

Test method:

Annex C,

Deviation from Austria, C.2.2, C.2.3

Sample tested:

ECO TOP 33

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement		Requirement specification	Test evaluation
Boiler efficiency for nominal h	eat output and minimum	Woo	Wood Pellets – C1
Boiler	Minimum efficiency		
Heating boilers for solid fuels	75 %		+
a) manually loaded		ČSN EN 303-	
up to 10 kW	79 %	5:2013 Annex C,	
>10 to 200 kW	(71.3 + 7.7 log Pn) %		
>200 kW	89 %	Deviation from	
a) automatically loaded		Austria, C.2.2	
up to 10 kW	80 %		
>10 to 200 kW	(72.3 + 7.7 log Pn) %		+
>200 kW	90 %		
NOTE Pn is the nominal heat ard)	output (Qn in this stand-		

Require	ment			Requirement specification	Test evaluation			
Emissio	n limits			-				
Small bu	rners used for	solid fuels a		Maria Dalla Ca				
		Emission mg-N		ľ	Wood Pellets – C1			
Parameter	Wooden Wood Pellets Room heaters	Wooden Wood Pellets Central heaters	Other wooden fuels	Other standard- ised biogenous fuels	ČSN EN 303- 5:2013			
co	500°	250°	250 ª	500°	Annex C, Deviation from			
NO _x	100	100	100	300	Austria, C.2.3			
OGC/THC	30	20	30	20		+		
Dust	25	20	30	35				

The limit value can be exceeded by 50 % during partial load operation at 30 % of nominal heat output.



Measurement results: ECO TOP 33 - Wood pellets - C1

Boiler output	Minimum efficiency	Measured efficiency
Nominal	04.0	93.7
Minimum	84.0	90.0

Test evaluation:

The measured efficiency of ECO TOP 33 - Wood pellets - C1 is higher than required.

Measurement results: ECO TOP 33 - Wood pellets - C1

	Average values											
Boiler		N	<i>l</i> leasure	d values		Converted values O₂=0%						
output	O ₂ [%]	CO [ppm]	NO _x [ppm]	OGC/THC [ppm]	Dust [mg/m³]	CO [mg/MJ]	NO _X [mg/MJ]	OGC/THC [mg/MJ]	Dust [mg/MJ]			
Nominal	8.85	238	72	6	32	126	62	4	14			
Minimum	12.70	184	51	4	26	142	65	4	16			

Test evaluation:

The measured emission values for ECO TOP 33 - Wood pellets - C1 do not exceed the specified values.



Accredited test number:

1004.1* Test title:

1005.1*

Test of heat output, input and efficiency Combustion efficiency test - emissions

ČSN EN 303-5:2013

Test method:

Annex C,

Deviation from Denmark, C.4.1, C.4.2

Sample tested:

ECO TOP 33

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement		Requirement specification	Test evaluation
	Construction Code BR08, boilers for coal, coke, bio fuel iciency equivalent to Class 3	ČSN EN 303- 5:2013	Wood Pellets – C1
Minimum efficiency	linimum efficiency (67 + 6 log Qn) %		+
For boilers above 300 kW, the 300 kW shall be used.	requirement corresponding to	C.4.1	

Requiren	nent		Requirement specification	Test evaluation				
Emission	limits		21		-			
		anish EPA Statut lass 3 (or higher)						
			Emissi	on limit va	alues ^a			
Stoking	Fuel	Nominal heat output	со	OGC/ THC Dust			Weed Dellete CA	
	iuei		mg-	m³ at 10%	O ₂	ČSN EN 303-	Wood Pellets – C1	
	1	kW		Class		1		
			3		5:2013			
	D	≤ 50	5000	150	150	Annex C,		
	Biogenic	> 50 to 150	2500		150	Deviation from		
Manual	<u> </u>	> 150 to 300	1200	450		Denmark,		
	Fossil	≤ 50 > 50 to 150	5000	150	405	· ·		
	FOSSII	> 150 to 150	2500		125	C.4.2		
	-	1	1200	100				
	D:	≤ 50	3000		450		+	
	Biogenic	> 50 to 150	2500	80	150			
Automatic		> 150 to 300	1200					
		≤ 50	3000	100				
	Fossi!	> 50 to 150	2500	80	125			
		> 150 to 300	1200					
a Referring t	o dry exit flu	e gas, 0 °C, 1 013 mba	r					



Measurement results: ECO TOP 33 - Wood pellets - C1

Boiler output	Minimum efficiency	Measured efficiency
Nominal	76.1	93.7
Minimum	76.1	90.0

Test evaluation:

Measured efficiency for ECO TOP 33 - Wood pellets - C1 is higher than required.

Measurement results: ECO TOP 33 - Wood pellets - C1

	Average emission values										
Boiler output		Measure	d values		Converted values O ₂ =10%						
	O ₂ [%]	CO [ppm]	OGC/THC [ppm]	Dust [mg/m³]	CO [mg/m³]	OGC/THC [mg/m ³]	Dust [mg/m³]				
Nominal	8.85	238	6	32	270	8	29				
Minimum	12.70	184	4	26	304	8	34				

Test evaluation:

The measured emission values for ECO TOP 33 - Wood pellets - C1 do not exceed the specified values.



Accredited test

1004.1* Test title: Test of heat output, input and efficiency

number:

1005.1*

Combustion efficiency test - emissions

ČSN EN 303-5:2013

Test method:

Annex C,

Deviation from Germany, C.5.1, C.5.2

Sample tested:

ECO TOP 33

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement				Requirement specification	Test evaluation	
Emission limi	ts					
Table 7 – Emis	sion limits					
4, 5 and Annex Control Ordina Bundes-Immiss über kleine und Boilers operate sess the quality	limits are regula c 2 of the Germa nce "Erste Vero sionsschutzges d mittlere Feuer ed with solid fue y and be put into ng specification	an Immission ordnung zur Eetzes (Verordungsanlagen els shall only lo operation if	ČSN EN 303- 5:2013	Wood Pellets – C1		
	Fuel acc. to §3 (1)	Nominal output range kW	Annex C, Deviation from Germany, C.5.1			
Stage 2: Appliances,	Numbers 1 to 5a	≥ 4	0.02	0.4		ž.
which will be installed	Numbers 6 to 7	≥ 30 ≤ 500	0.02	0.4		
after 31.12.2014	INGUIDEIS O (O 1	> 500	0.02	0.3		
	Numbers 8 to 13	≥ 4 < 100	0.02	0.4		iola according \$2 article 4 Num

NOTE Differing from sentence 1 for firing systems (appliances) which will exclusively be fired by fuels according §3 article 1 Number 4 in the form of split logs, the limits according Stage 2 apply for firing systems (appliances) if they are installed after 31.12.2016.




Measurement results: ECO TOP 33 - Wood pellets - C1

Boiler output	Average emission values				
	Measured values			Converted values O _z =13%	
	O ₂ [%]	CO [ppm]	Dust [mg/m³]	CO [g/m³]	Dust [g/m³]
Nominal	8.85	238	32	0.196	0.021
Minimum	12.70	184	26	0.221	0.025

Test evaluation:

The measured emission values for ECO TOP 33 - Wood pellets - C1 exceed the specified values.





Accredited test number:

1004.1* Test title: Test of heat output, input and efficiency

1005.1*

Combustion efficiency test - emissions

ČSN EN 303-5:2013

Annex C

C.6 Deviation from Switzerland

Sample tested:

Test method:

ECO TOP 33

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Re	equirement	Requirement specification	Test evaluation		
Emission limits Clause 4.4.7, Table 7 The emission limits are regulated in Annex 4 of the Swiss Ordinance on Air Pollution Control ([OAPC] SR 814.318.142.1) of 1985-12-16 (as at 2010-07-15). Boilers operated with woody biomass shall only be put on the market if they fulfil the following specifications of the OAPC: - declarations of conformity (Figure 20 OAPC); - Figures 1, 212, 23 Annex 4 OAPC; - Figures 31, 32 Annex 5 OAPC. Emissions for boilers operated with coal or wood fuels shall not exceed the following limits: Particular requirements (emission limits) ^a for carbon			ČSN EN 303- 5:2013 Annex C C.6 Deviation from Switzer-	Wood Pellets - C1	
Type of installation	Type of installation monoxide (CO) and particulate matter (dust)		land		
Boilers for log wood and boilers for coal, manual stoking	CO (mg-m³) 800	Dust (mg-m³) 50			
Boilers for chipped wood and boilers for coal, automatic stoking	400	60		_	
Boilers for Wood Pellets, automatic stoking	1 300 1 701			+	
^a Referred to oxygen basis: – for boilers for natural state – for boilers for coal 7 % volution The sulphur content of coal, woody biomass shall comply – Figures 741, 742, 743 Anno – Figures 81, 82 Annex 3 OA According to Figure 743, Ar	me. coal briquettes and with the following spe ex 2 OAPC; PC.	ecifications of the C	DAPC:	0	

According to Figure 743, Annex 2 OPAC, non-woody biomass, such as biogenic waste and products from agriculture, may only be burnt in boilers with a heat input of at least 70 kW. Such units need an approval and shall meet stronger emission limits according to Figure 742, Annex 2 OAPC.



Measurement results: ECO TOP 33 - Wood pellets - C1

Boiler output	Average emission values				
	Measured values			Converted values O ₂ =13%	
	O ₂ [%]	CO [ppm]	Dust [mg/m³]	CO [mg/m³]	Dust [mg/m³]
Nominal	8.85	238	32	196	21
Minimum	12.70	184	26	221	25

Test evaluation:

The measured emission values for ECO TOP 33 - Wood pellets - C1 do not exceed the specified values.



Accredited test

1006.1* Test title:

number:

1005.1* Function test of control, regulation and safety elements

Combustion efficiency test - emissions

ČSN EN 303-5:2013

Art. 5.13, 5.14, 5.16.1, 5.16.2, 5.16.3

ČSN EN 303-5:2013

Art. 5.9, 5.10.4

Sample tested:

Test method:

ECO TOP 33

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement	Requirement specification	Test evaluation	Note
Function check of the temperature controller and safety temperature limiter at the boiler			
The water-side flow rate shall comply with that specified for the nominal heat output test. The flow temperature of 75 °C shall not be exceeded at the start of the test °C.			
Adjust the firing so that it corresponds to the nominal heat output Q_{N} of the boiler. A steady state condition shall be reached and the outlet pressure at the flue gas section shall be according to the nominal heat output setting. For manual stoked boilers, the boiler shall be refuelled after reaching steady state with a full batch before starting the test.			
The dissipated output shall be reduced to (40 ± 5) % of the nominal heat output of the boiler, circulating pump running in continuous operation; temperature controller adjusted to maximum set value.	ČSN EN 303- 5:2013 Art. 5.13	+	
When the temperature controller is operating normally, the measured flow temperature shall not exceed 100 °C; the safety temperature cut out or limiter or the device for dissipating excess heat shall not trigger.			
Repeat the test with the temperature controller out of function. This time, check if the safety temperature limiter-detector switches off the firing system at the highest value specified by the boiler manufacturers and if all hazardous operation states are avoided (see 4.1).			

Report 31-9690/T Page 22 of 24



Requirement	Requirement specification	Test evalua- tion	Note
Function test for the rapidly disconnectable firing system	-		
Sudden absence of heat dissipation			
The water-side flow rate shall comply with that specified for the nominal output test. The flow temperature of 75 °C shall not be exceeded at the start of the test.			
Adjust the firing so that it corresponds to the nominal heat output Q_N of the boiler, a steady state condition is reached and the outlet pressure at the flue spigot is according to the rated heat output.			
The heat consumption is set to 0; water circulation in the boiler is permitted; temperature controller is adjusted to manufacture recommended maximum set value.			
Check if the safety temperature limiter or the temperature controller switches off the firing system and all hazardous operation states are avoided.	ČSN EN 303- 5:2013 Art. 5.14	+	
- Loss of the electrical power supply			
The water-side flow rate shall comply with that specified for the nominal heat output test. The flow temperature of 75 °C shall not be exceeded at the start of the test.			
Adjust the firing so that it corresponds to the nominal heat output Q_N of the boiler, a steady state condition is reached and the outlet pressure at the flue gas section is according to the rated heat output.			
The electrical power supply including the circulation is cut off, check that no hazardous operation conditions occur.			
For the evaluation of the temperatures and the CO-concentrations, only mean values at a maximum average time of one minute shall be considered.			
Safety test of consequences of fuel overload and effect of a blockage of the fuel supply The safety of the boiler shall be checked at continuous operation of the boiler with the fuel feed rate of the stoking device set at possible maximum capacity, taking into account failures according to the risk analyses and the electrical safety. If other fuel feed rates lower than the maximum are categorised as critical by the risk analysis, these shall also be tested. The functionality of the safety device for the shut-down of the fuel shall occur by prevention of the ignition after release of fuel if no or insufficient combustion in the combustion chamber occurs. The test for blocked fuel line shall be achieved by deactivating the stoking device. The requirements specified in 4.3.4 shall be satisfied.	ČSN EN 303- 5:2013 Art. 5.16.2	+	



Requirement	Requirement specification	Test evalua- tion	Note
Loss of combustion air supply The safety of the heating boiler shall be checked at maximum heat input under the following conditions:			
 failure of combustion air fan; failure to close of the adjustable combustion air supply. 	ČSN EN 303- 5:2013		
In each case, only one failure shall be simulated. The CO concentrations in the boiler shall not exceed 5 % volume.	Art. 5.16.3	+	
The measurement of CO concentration shall be carried out in the flue gas measuring section. Test of combustion air supply loss			

Note:

- Compliant Non-compliant Not applicable
- 0
- Not assessed Х

Measurement results:

Temperature controller				
Temperature	[°C]	Note:		
Pre-set	80	Temperature set on the operating thermostat regulator		
Shutdown	82	Fan and stoking switched off (suppression mode)		
Restoration of operation	69	Fan and stoking restored		

Temperature limiter (manual restoration of temperature) STB					
Temperature	[.c]	Note:			
Pre-set	95 Temperature set on the temperature				
Shutdown	99	99 Fan and stoking switched off			
Restoration of operation	tion, a manual	The boiler irreversibly switched off. In order to restore operation, a manual intervention required, after the temperature drops under the limiter switching temperature			

Test evaluation:

Proper functioning of safety elements has been verified.

Tested by:	Ing. Pavel Fojtů	Date:	05/2016	Signed:
Reviewed by:	Ing. Stanislav Buchta	Date:	06/2016	Signed: R-L-

V. List of source materials

The tests were performed based on

- Order B-53642 dated 2015-08-10 (received on 2015-08-11)
- Contract B-53642/31
- Amendment D1, D2 and D3 of Contract B-53642/31
- ČSN EN 303-5:2013 Heating boilers Part 5: Heating boilers for solid fuels, manually and automatically stoked, nominal heat output of up to 500 kW Terminology, requirements, testing and marking

Test report compiled by:

Ing. Pavel Fojtů

The persons named below are accountable for the accuracy of the above-specified data:

Milan Holomek Head of Heat and Environment-Friendly Equipment Test Station



